

# CARSO - LABORATOIRE SANTÉ ENVIRONNEMENT HYGIÈNE DE LYON

Laboratoire Agréé pour les analyses d'eaux par le Ministère de la Santé

Laboratoire habilité par le Ministère chargé de la santé en application de l'article R\*.1321-52 du code de la santé publique

## ATTESTATION DE CONFORMITE SANITAIRE

### Certificate of sanitary conformity

Conformément à l'arrêté du 29 mai 1997 modifié et à la circulaire du Ministère de la Santé  
Direction Générale de la Santé DGS/SD7A N° 571 du 25 Novembre 2002

#### Coordonnées du demandeur d'ACS / Contact details of the ACS owner :

**OFFICINE RIGAMONTI S.P.A.**

**Via Circonvallazione, 9**

**13018 VALDUGGIA (VC)**

**Italie**

#### Nom de l'accessoire représentatif / Reference of the representative accessory :

Réducteur de pression à piston, corps extérieur nickelé et intérieur en laiton brut /

**Pressure reducing valve, nickel plated outside and nude brass inside body PN25 M-M 3/4" Art. 234.120**

#### N° de dossier attribué par le laboratoire habilité / File reference :

**19 ACC LY 440**

Date de réalisation des essais d'inertie selon la norme XP P41-280 : aucun essai de migration n'est nécessaire

Tests date (according to the standard XP P 41-280) : No testing is required to issue this ACS

Commentaires : Aucun essai de migration n'est nécessaire à l'obtention de cette ACS (composants conformes).

Comments : No testing is required to issue this ACS (components are compliant).

#### Famille d'accessoires couverte par l'ACS / Accessories' family covered by this certificate :

**Réducteurs de pression à piston / Pressure reducing valves**

#### Références / References (7 références) :

#### Corps extérieur nickelé en intérieur en laiton brut / Nickel plated outside and nude brass body inside:

|  |   |
|--|---|
| PN25 Double Femelle Art. 233.1                     | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2", 2"1/2, 3", 4" |
| PN25 Union avec douille Male-Male Art. 234.1       | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2"                |
| PN25 Union avec douille Femelle-Femelle Art. 236.1 | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2"                |
| PN25 MDD Art. 233.0 & 233.9                        | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2", 2"1/2, 3", 4" |

#### Corps en laiton brut / Nude brass body :

|  |                                  |
|--|----------------------------------|
| PN25 Double Femelle Art. 233.180 & 233.200         | 3", 4"                           |
| PN25 Union avec douille Male-Male Art. 234.0       | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2" |
| PN25 Union avec douille Femelle-Femelle Art. 236.0 | 1/2", 3/4", 1", 1"1/4, 1"1/2, 2" |

#### Attestation délivrée par / Certificate issued by :

Christelle AUTUGELLE

Responsable MCDE

CARSO - L.S.E.H.L.

Signature :



Date de délivrance / Date of issue : 31 Juillet 2019

Date d'expiration / Expiry date : 31 Juillet 2024

Commentaires / Comments : Renouvellement / Renewal 14 ACC LY 666





By Royal Charter

## Kitemark™ Certificate

This is to certify that:

Officine Rigamonti SpA  
Via Circonvallazione, 9  
Valduggia (VC)  
13018  
Italy

Holds Certificate Number:

KM 618292

In respect of:

**BS EN 1567**

**Building valves. Water pressure reducing valves and combination water reducing valves**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Pietro Foschi - Strategic Delivery Director

First Issued: 25/02/2015

Latest Issue: 25/02/2015



Page: 1 of 2

...making excellence a habit.™

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 618292

**BS EN 1567:1999 - Building valves. Water pressure reducing valves and combination water reducing valves.**

## Description

PN25 Nickel plated pressure reducing valves with piston and compensating chamber with stainless steel seat.

## Model references and sizes (DN)

0233.115 – 1/2"

0233.120 – 3/4"

0233.125 – 1"

The above valves are intended for use in Fire Fighting Systems.



First Issued: 25/02/2015

Latest Issue: 25/02/2015

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.





**BUILDING RESEARCH INSTITUTE - CERTIFICATION COMPANY Ltd.**  
Notified Body Certification Body for Products, Qualification, EPD, Quality Buildings and Management Systems Testing Laboratory  
**Authorized Body 227**

# PRODUCT CERTIFICATE

No. 227/C5/2015/0280

The Authorized Body confirms in accordance with the provision of §5, clause 2 of the Government Order No.163/2002 Coll., in the wording of the Government Regulation No.312/2005 Coll., which stipulates technical requirements on the specified construction products, that for the product:

name of the product: **Water pressure reducing valve art. 233.1**

intended use: For reduction and control of pressure in heating systems and water distribution systems, which is not intended for human consumption.

producer **Officine Rigamonti spa**  
Via Circonvallazione 9, I-13018 Valduggia (VC), Italy code of the country: 380

the documentation submitted by the producer was reviewed, the initial type testing of the product samples was carried out, the production control system of the producer was assessed, and there was found out that the product meets the technical requirements specified at the determined standard ČSN EN 1567 and technical regulations, which relate to the essential requirements.

Authorized Body has found out that the production control system performed by the producer conforms to the relevant technical documentation and ensures that the products placed on the market meet the requirements established at the above mentioned technical regulations and the determined standard and conform to the technical documentation according to §4, clause 3.

Protocol No. 227-P5-15-0280 of 20<sup>th</sup> July 2015 which involves the results of the findings, verification and the test results, fundamental description of the certified product necessary for their identification, is an integral part of this certificate.

This certificate remains valid until the requirements specified at the determined standard and the technical regulations mentioned above or the production conditions at the place of production or the production control system do not change significantly.

Authorized Body 227 carries out at least once a year a surveillance on the proper operation of the production control system performed by the producer, takes product samples at the place of production, performs their tests and reviews if the product characteristics conform with technical regulations and the determined standard according to the provision of §5, clause 4 of the above mentioned Government Order. In case of any discrepancies, Authorized Body is justified to cancel or to change the certificate.

Copy No.: 1  
Place and date of issue:  
In Prague, on: 20 July 2015

K: 14363  
CS-V UCEN\_VPG27  
R11-20\_010713

Výzkumný ústav pozemních staveb - Certifikační společnost, s.r.o. 102 21 Praha 10 - Hostivař, Pražská 810 / 16  
IČ: 25052063 DIČ: CZ250 520 63 Tel.: 00420 271 751 148, Fax: 00420 281 017 241; E-mail: info@vups.cz www.vups.cz



Ing. Lubomír Keim, CSc.  
Head of Authorized body 227