



Sprinkler System Components | Water Motor Gongs | **Waterflow Alarm System Valves**

Model UVW.1511-300

Product Description

Model No	Description	Valve Size		Rated Working Pressure		End Connection	Remarks
		in	(mm)	psi	(kPa)		
UVW.1511-300	Alarm Check Valve	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Flanged	a, d, e

Remarks:

a. Resilient seat.

d. Only considered FM Approved when supplied with WEFLO Model RC-16 retard chamber

e. FM Approved for Vertical Installations Only

Details

Category	Waterflow Alarm System Valves
Class of Work	1041 - Alarm Check Valves
Approval Standard	FM 1041 - Alarm Check Valves
Certification Type	FM Approved
Listing Country	Turkiye

Company

GIACOMINI UNIVAL TESISAT
 ARMATÜRLERİ
 SANAYİ VE TİCARET LTD. STİ.,
 İstanbul Anadolu Yakası Organize
 Sanayi Bölgesi, Aydınli
 Mah.Mermerciler Cad. No: 10,
 Tuzla-Istanbul, Türkiye