



Certificate of Quality System Approval

This is to certify that the product listed below conforms to the requirements of the
Pressure Equipment (Safety) Regulations 2016
Schedule 1A Module H

Certificate Number HPIUK-P1057-071-Q-03-00
Date of Issue 27-Jun-2023
Date of Expiry 25-Apr-2025
Date of Surveillance 25-Apr-2024
Manufacturer **Giacomini Unival Tesisat Armatürleri Sanayi Ve Ticaret Limited Şirketi.**
Köseler Mahallesi 10. Sk. No.4 Dilovası, Kocaeli, Türkiye

Description of Pressure Equipment
Ball Valve: DN15-300, PN16 / PN25, TS 3148:2009, EN ISO 17292:2015
Butterfly Valve: DN15-400, PN16 / PN25, EN 593:2017
Strainer: DN15-400, PN16 / PN25, TS 11494:1994
Gate Valve: DN15-300, PN16 / PN25, TS EN 1171:2015
Check Valve: DN15-300, PN16 / PN25, EN 1074-1:2000
Control Valve: DN50-300, PN16 / PN25
Balancing Valve: DN50-300, PN16, EN 13789:2010
Metal Hose: DN15-DN50, PN16 / PN25
Metal Expansion Joint: DN25 -DN250, PN16 / PN25, TS 10880:2016

Equipment Identification UKCA dataplate on each Category I, II and III valve

Type of material Cast irons

Other Certification ISO 9001:2015 Quality Management System Certificate no. GC-18-2147 issued by Goldcert

Standards Applied See description

Report Reference HPiVS-iP1057-071-5

This Certificate is valid in Great Britain.

This Report has been issued by HPi Verification Services Ltd. which is an Approved Body according to the provisions of the Pressure Equipment (Safety) Regulations 2016 (Approved Body number 1521).

This Report is issued following the assessment of the documentation and implementation of the Quality System in accordance with the provisions of the quoted Conformity Assessment Module of the above regulations. The UK Mark may be affixed to the Pressure Equipment within the scope of approval as described above once the 'declaration of conformity' has been signed by the responsible person. The number '1521', being HPi Verification Services Ltd's Approved Body number should also be placed on the equipment dataplate.

Check this certificate is genuine



Quality Director

Technical Director

A UKAS



UK Approved Body No. 1521

Company registered in England #7217086

© HPi Verification Services Ltd. 2022

Tel +44 1491 822818

Email enquiries@hpivs.com

www.hpivs.com

HPi Verification Services Ltd.

The Manor House

Howbery Park, Wallingford

OX10 8BA, United Kingdom