

Approvals

Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

UV0001

Details

Category	Non-Storage Sprinklers
Class of Work	2012 - AS, Control Mode, Sidewall
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Coverage Type	Standard
Type	Horizontal Sidewall
Response	SR - Standard Response
Element	5 mm
NPT (in.)	1/2
Finish	Brass, Chrome, Polyester
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
Listing Country	Turkiye

Company

GIACOMINI UNIVAL TESISAT
ARMATÜRLERİ
SANAYİ VE TİCARET LTD. STİ.,
İstanbul Anadolu Yakası Organize
Sanayi Bölgesi, Aydınlı
Mah.Mermerciler Cad. No: 10,
Tuzla-İstanbul, Türkiye