

Extinguishing System Attachments

COMPANY

GIACOMINI UNIVAL TESISAT ARMATURLERI SANAYI VE TICARET LTD.STI.
 ISTANBUL ANADOLU TAKASI ORGANIZE SANAYI BOLGESI 1
 Sokak No 4. MERMERCILER CAD
 Tuzla Istanbul, Istanbul 34953 Turkey

S36812

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Supervisory switches, Models UVFS-PI, UVOSY-2

Wet Pipe, Paddle Type

Model	Size In.	Pipe Schedule	Max System Pressure psig
UVFS	2.00	10 through 40	365
	2.5	10 through 40	365
	3.0	10 through 40	365
	4.0	10 through 40	365
	5.0	10 through 40	365
	6.0	10 through 40	365
	8.0	10 through 40	365

Last Updated on 2023-09-08

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."