

Sprinkler System Components | Branch Line Alarm Testers | **Sprinkler System Alarm Testers**

Model A61

Product Description

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
A61	1	(25)	2.8, 4.2, 5.6, 8.0	300	(2065)	a
A61	1 1/4	(32)	2.8, 4.2, 5.6, 8.0, 11.2, 14.0	300	(2065)	a, b
A61	2	(50)	4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4, and 25.2	300	(2065)	a, b

Remarks:

a. Devices supplied with female NPT or BSPP threaded end connections.

b. Devices supplied with grooved end connections.

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved
Listing Country	Italy

Company

Giacomini SpA

Via per Alzo 39, 28017 San Maurizio d'Opaglio (NO) Italy

<http://giacomini.com>