



Models UVOSY-2 & UVFS-PI

Certificate Number: **FM23FPUS0200**

Company

GIACOMINI UNIVAL TESISAT ARMATÜRLERİ

SANAYİ VE TİCARET LTD. STİ., İstanbul Anadolu Yakası Organize Sanayi Bölgesi, Aydınlı Mah.Mermerciler Cad. No: 10, Tuzla-Istanbul, Türkiye

Detection, Fire Alarm and Signaling Equipment | Sprinkler Valve Position Devices | **Sprinkler System Supervision, Standard Security**

Models UVOSY-2 & UVFS-PI Series

Description of Equipment:

UVOSY-2 & UVFS-PI Series Supervisory Switches

Model	Size	Description
UVOSY-2	D50(2"),D450(18")	Supervisory Switch for YS&Y Gate Valve
UVFS-PI	1/2"	Supervisory Switch for Indicator Post

Rated IP65

Details

Category	Sprinkler System Supervision, Standard Security
Class of Work	3135 - Sprinkler Valve Pos Sw
Certification Type	FM Approved
Listing Country	Türkiye
Certificate Number	FM23FPUS0200