



Certificate of Compliance

This certificate is issued for the following:

Angle Hose Valves

Models A55E, A56E, A55EG, and A56EG
(see listing attached)

Prepared for:

Giacomini SpA
Via per Alzo 39
28017 San Maurizio d'Opaglio (NO)
Italy

FM Approvals Class: 1521 (December 2014)

Approval Identification: PR454140

Approval Granted: March 12, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Model No	Description	Valve Size		Rated Working Pressure		Remarks
		in	(mm)	psi	(kPa)	
A55	Standard Hose Valves FemaleConnection x Female Connection	1 1/2, 2 1/2	(38, 64)	300	(2070)	
A55H	Standard Hose Valves Grooved x Female Connection FemaleConnection x Female Connection	2 1/2	(64)	500	(3445)	
A56	Standard Hose Valves FemaleConnection x Male Connection	1 1/2, 2 1/2	(38, 64)	300	(2070)	
A56H	Grooved x Male Connection FemaleConnection x Male Connection	2 1/2	(64)	500	(3445)	
A155	Pressure Restricting Hose Valve Standard Hose Valves FemaleConnection x Female Connection	1 1/2, 2 1/2	(38, 64)	300	(2070)	a
A156	Pressure Restricting Hose Valve FemaleConnection x Male Connection	1 1/2, 2 1/2	(38, 64)	300	(2070)	a
A55G	Standard Hose Valves Grooved x NPT	2 1/2	(64)	300	(2070)	
A56G	Standard Hose Valves Grooved x NST	2 1/2	(64)	300	(2070)	
A156G	Standard Hose Valves Grooved x NYCT	2 1/2	(64)	300	(2070)	a
A55E	Standard Hose Valve Female x Female NPT	2 1/2	(64)	300	(2070)	
A55EG	Standard Hose Valve Groove x Female NPT	2 1/2	(64)	300	(2070)	
A56E	Standard Hose Valve Male NHT x Female NPT	2 1/2	(64)	300	(2070)	
A56EG	Standard Hose Valve Groove x Male NHT	2 1/2	(64)	300	(2070)	

Remarks: a. For pressure restricting hose valve settings review operation manual.





Certificate of Compliance



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Angle and Straightaway Hose Valves

Model No	Description	Valve Size		Rated Working Pressure	
		in	(mm)	psi	(kPa)
A55E	Standard Hose Valve Female x Female NPT	1 1/2, 2 1/2	(38, 64)	300	(2070)
A56E	Standard Hose Valve Male NHT x Female NPT	1 1/2, 2 1/2	(38, 64)	300	(2070)

Prepared for:

Giacomini SpA
Via per Alzo 39
28017 San Maurizio d'Opaglio (NO)
Italy

Approval Standard: FM 1521, 1522 (December 2014)

Approval Identification: PR460711

Approval Granted: March 28, 2022

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

