

Fixed Extinguishing Systems | Deluge and Preaction Systems | Dry Pipe System Valves

Model UVD.2511-300

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection	Remarks
	in	(mm)	psi	(kPa)	End Connection	Remarks
UVD.2511-300	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Flanged	a, b, c, d

Remarks:

a. Approved for vertical installation only

b. Approved when supplied with a main control valve body ASTM A536 ductile iron

c. Approved when supplied with FM Approved pressure gauges

d. Approved when supplied with one or more of the following optional components: dry accelerator assembly, FM Approved pressure switch and FM Approved water motor gong.

Details

Class of Work : 1021 - Dry Pipe Valves Approval Standard : FM 1021 - Dry Pipe Valves Certification Type : FM Approved Listing Country : Turkiye Category : Dry Pipe System Valves

Company

GIACOMINI UNIVAL TESISAT ARMATÜRLERI

SANAYI VE TICARET LTD. STI., Istanbul Anadolu Yakasi Organize Sanayi Bölgesi, Aydinli Mah.Mermerciler Cad. No: 10, Tuzla-Istanbul, Turkiye Turkiye

Confirm



Cookies help us improve your website experience. By using our website, you agree to our use of cookies.

Confirm