

HMER.EX15304 - Check Valves

Check Valves

[See General Information for Check Valves](#)

RAPIDROP GLOBAL LTD
RUTLAND BUSINESS PARK
NEWARK RD
PETERBOROUGH, PE1 5WA UNITED KINGDOM

EX15304

		Valve Seat Facing	Nom Pipe Size, NPS	End Config	Rated Pressure, psig	Installation Position
Model	Type					
302	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
304-060	Swing	Elastomeric	2	G by G	350	H, V
304-073	Swing	Elastomeric	2-1/2	G by G	350	H, V
304-076	Swing	Elastomeric	2-1/2	G by G	350	H, V
304-089	Swing	Elastomeric	3	G by G	350	H, V
304-114	Swing	Elastomeric	4	G by G	350	H, V
304-139	Swing	Elastomeric	5	G by G	350	H, V
304-141	Swing	Elastomeric	5	G by G	350	H, V
304-165	Swing	Elastomeric	6	G by G	350	H, V
304-168	Swing	Elastomeric	6	G by G	350	H, V
304-219	Swing	Elastomeric	8	G by G	350	H, V
305-050	Swing	Elastomeric	2	F by F	350	H, V
305-065	Swing	Elastomeric	2-1/2	F by F	350	H, V
305-080	Swing	Elastomeric	3	F by F	350	H, V
305-100	Swing	Elastomeric	4	F by F	350	H, V
305-125	Swing	Elastomeric	5	F by F	350	H, V
305-150	Swing	Elastomeric	6	F by F	350	H, V
305-200	Swing	Elastomeric	8	F by F	350	H, V
CVF300	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8,10, 12	F by F	300	H, V
301	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	300	H, V
302 PN16	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
303	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	300	H, V

End Configuration:

F - Flanged


G - Grooved

W - Wafer

Installation Position:

H - Horizontal installation

V - Vertical installation

Trademark and/or Tradename: "Rapidrop" , Last Updated on 2019-07-17

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"