

FM Approvals

Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

UV341

Details

Category	Non-Storage Sprinklers
Class of Work	2012 - AS, Control Mode, Sidewall
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Coverage Type	Standard
Type	Horizontal Sidewall
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Polyester, Black Teflon, Chrome, Brass
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141
Sprinkler Category	Non Storage
Vakum sistemiyle birlikte kullanın.	HAYIR
Oluklu Bağlantı	HAYIR

Company

GIACOMINI UNIVAL TESISAT
ARMATÜRLERİ
SANAYİ VE TİCARET LTD. STİ.,
İstanbul Anadolu Yakası Organize
Sanayi Bölgesi, Aydınli
Mah.Mermerciler Cad. No: 10,
Tuzla-İstanbul, Türkiye

FM Approvals

Listeleme Ülkesi Türkiye